

**West Virginia Department of Environmental Protection
Division of Air Quality**

*Randy C. Huffman
Cabinet Secretary*

Permit to

Operate



*Pursuant to
Title V
of the Clean Air Act*

Issued to:
Dominion Transmission, Inc.
Deep Valley Compressor Station
R30-09500007-2010

*John A. Benedict
Director*

Issued: November 30, 2010 • Effective: December 14, 2010
Expiration: November 30, 2015 • Renewal Application Due: May 30, 2015

Permit Number: **R30-09500007-2010**
Permittee: **Dominion Transmission, Inc.**
Facility Name: Deep Valley Compressor Station
Mailing Address: 445 West Main Street
Clarksburg, WV 26301

This permit is issued in accordance with the West Virginia Air Pollution Control Act (West Virginia Code §§ 22-5-1 et seq.) and 45CSR30 — Requirements for Operating Permits. The permittee identified at the above-referenced facility is authorized to operate the stationary sources of air pollutants identified herein in accordance with all terms and conditions of this permit.

Facility Location:	Deep Valley, Tyler County, West Virginia
Mailing Address:	CR 56/1 Deep Valley, WV 26415
Telephone Number:	(304) 873-1923
Type of Business Entity:	Corporation
Facility Description:	Natural Gas Transmission Facility
SIC Codes:	4922
UTM Coordinates:	512.34 km Easting • 4355.01 km Northing • Zone 17

Permit Writer: Rex Compston

Any person whose interest may be affected, including, but not necessarily limited to, the applicant and any person who participated in the public comment process, by a permit issued, modified or denied by the Secretary may appeal such action of the Secretary to the Air Quality Board pursuant to article one [§§ 22B-1-1 et seq.], Chapter 22B of the Code of West Virginia. West Virginia Code §22-5-14.

Issuance of this Title V Operating Permit does not supersede or invalidate any existing permits under 45CSR13, 14 or 19, although all applicable requirements from such permits governing the facility's operation and compliance have been incorporated into the Title V Operating Permit.

Table of Contents

1.0	Emission Units and Active R13, R14, and R19 Permits	4
1.1.	Emission Units	4
1.2.	Active R13, R14, and R19 Permits	5
2.0	General Conditions.....	6
2.1.	Definitions	6
2.2.	Acronyms	6
2.3.	Permit Expiration and Renewal	7
2.4.	Permit Actions	7
2.5.	Reopening for Cause	7
2.6.	Administrative Permit Amendments	8
2.7.	Minor Permit Modifications	8
2.8.	Significant Permit Modification.....	8
2.9.	Emissions Trading	8
2.10.	Off-Permit Changes	8
2.11.	Operational Flexibility	9
2.12.	Reasonably Anticipated Operating Scenarios	10
2.13.	Duty to Comply.....	10
2.14.	Inspection and Entry	10
2.15.	Schedule of Compliance	11
2.16.	Need to Halt or Reduce Activity not a Defense	11
2.17.	Emergency	11
2.18.	Federally-Enforceable Requirements.....	12
2.19.	Duty to Provide Information	12
2.20.	Duty to Supplement and Correct Information	12
2.21.	Permit Shield	12
2.22.	Credible Evidence.....	13
2.23.	Severability	13
2.24.	Property Rights	13
2.25.	Acid Deposition Control.....	13
3.0	Facility-Wide Requirements	15
3.1.	Limitations and Standards.....	15
3.2.	Monitoring Requirements	16
3.3.	Testing Requirements	17
3.4.	Recordkeeping Requirements	18
3.5.	Reporting Requirements	19
3.6.	Compliance Plan	21
3.7.	Permit Shield	21
3.8.	Emergency Operating Scenario.....	21
4.0	Source-Specific Requirements [RBR01]	23
4.1.	Limitations and Standards.....	23
4.2.	Monitoring Requirements	23
4.3.	Testing Requirements	23
4.4.	Recordkeeping Requirements	24
4.5.	Reporting Requirements	24

4.6.	Compliance Plan	24
5.0	Source-Specific Hazardous Air Pollutant Requirements (Natural Gas Dehydration Units (DEHY01) Not Subject to MACT Standards and being controlled by a Flare Control Device (F1) [DEHY, DEHY01].....	25
5.1.	Limitations and Standards.....	25
5.2.	Monitoring Requirements	28
5.3.	Testing Requirements	29
5.4.	Recordkeeping Requirements	30
5.5.	Reporting Requirements	32
5.6.	Compliance Plan	33
<u>6.0.</u>	<u>Emergency Generators [emission point ID(s): 002-01, 002-02].....</u>	<u>34</u>
<u>7.0.</u>	<u>Engines [emission point ID(s): EN01, EN02].....</u>	<u>35</u>
<u>Attachment: G60-C029, G60-C</u>		

1.0 Emission Units and Active R13, R14, and R19 Permits

1.1 Emission Units

Emission Unit ID	Emission Point ID	Emission Unit Description	Year Installed	Design Capacity	Control Device
001-01*	EN01	Reciprocating Engine/Integral Compressor; Ajax DPC-800; 2SLB	1989	800 HP	N/A
001-02*	EN02	Reciprocating Engine/Integral Compressor; Ajax DPC-800; 2SLB	1989	800 HP	N/A
003-01*	DEHY01	Dehydration Unit Still; Tulpro	1989	0.693 mmscf/hr 18 mmscf/day	F1
004-01*	RBR01	Dehydration Reboiler; Tulpro	1989	960 scf/hr	N/A
0001*	DEHY	Dehydration unit flare pilot	1989	18.5 scf/hr	N/A
TK01	TK01	Horizontal Above Ground Ethylene Glycol Storage Tank	2008	1000 gallons	N/A
TK02	TK02	Horizontal Above Ground Tri-Ethylene Glycol Storage Tank	1998	1000 gallons	N/A
TK03	TK03	Horizontal Above Ground Waste Water Storage Tank	2003	230 gallons	N/A
TK04	TK04	Horizontal Above Ground Produced Fluids Storage Tank	2008	4000 gallons	N/A
TK05	TK05	Horizontal Above Ground Lube Oil Storage Tank	2008	3040 gallons	N/A
TK06	TK06	Vertical Above Ground Waste Water Storage Tank	2003	500 gallons	N/A
TK07	TK07	Horizontal Above Ground Used Oil Storage Tank	2008	1000 gallons	N/A
F1	F1	Dehydration Unit Controlled Flare	1989	5 MMBTU/hr	N/A
EG01*	002-01	Emergency Generator, Cummins GM 8.1L; 4SRB	2012	192.5 HP	S1
EG02*	002-02	Emergency Generator, Cummins GM 8.1L; 4SRB	2012	192.5 HP	S2

*This equipment burns or combusts pipeline quality natural gas only.

1.2. Active R13, R14, and R19 Permits

The underlying authority for any conditions from R13, R14, and/or R19 permits contained in this operating permit is cited using the original permit number (e.g. R13-1234). The current applicable version of such permit(s) is listed below.

Permit Number	Date of Issuance
R13-1104E	June 22, 2010
G60-C029	February 10, 2011

2.0 General Conditions

2.1. Definitions

- 2.1.1. All references to the "West Virginia Air Pollution Control Act" or the "Air Pollution Control Act" mean those provisions contained in W.Va. Code §§ 22-5-1 to 22-5-18.
- 2.1.2. The "Clean Air Act" means those provisions contained in 42 U.S.C. §§ 7401 to 7671q, and regulations promulgated thereunder.
- 2.1.3. "Secretary" means the Secretary of the Department of Environmental Protection or such other person to whom the Secretary has delegated authority or duties pursuant to W.Va. Code §§ 22-1-6 or 22-1-8 (45CSR§30-2.12.). The Director of the Division of Air Quality is the Secretary's designated representative for the purposes of this permit.
- 2.1.4. Unless otherwise specified in a permit condition or underlying rule or regulation, all references to a "rolling yearly total" shall mean the sum of the monthly data, values or parameters being measured, monitored, or recorded, at any given time for the previous twelve (12) consecutive calendar months.

2.2. Acronyms

CAAA	Clean Air Act Amendments	NSPS	New Source Performance
CBI	Confidential Business Information		Standards
CEM	Continuous Emission Monitor	PM	Particulate Matter
CES	Certified Emission Statement	PM₁₀	Particulate Matter less than
C.F.R. or CFR	Code of Federal Regulations		10µm in diameter
CO	Carbon Monoxide	pph	Pounds per Hour
C.S.R. or CSR	Codes of State Rules	ppm	Parts per Million
DAQ	Division of Air Quality	PSD	Prevention of Significant
DEP	Department of Environmental		Deterioration
	Protection	psi	Pounds per Square Inch
FOIA	Freedom of Information Act	SIC	Standard Industrial
HAP	Hazardous Air Pollutant		Classification
HON	Hazardous Organic NESHAP	SIP	State Implementation Plan
HP	Horsepower	SO₂	Sulfur Dioxide
lbs/hr or lb/hr	Pounds per Hour	TAP	Toxic Air Pollutant
LDAR	Leak Detection and Repair	TPY	Tons per Year
m	Thousand	TRS	Total Reduced Sulfur
MACT	Maximum Achievable Control	TSP	Total Suspended Particulate
	Technology	USEPA	United States
mm	Million		Environmental Protection
mmBtu/hr	Million British Thermal Units per		Agency
	Hour	UTM	Universal Transverse
mmft³/hr or	Million Cubic Feet Burned per		Mercator
mmcf/hr	Hour	VEE	Visual Emissions
NA or N/A	Not Applicable		Evaluation
NAAQS	National Ambient Air Quality	VOC	Volatile Organic
	Standards		Compounds
NESHAPS	National Emissions Standards for		
	Hazardous Air Pollutants		
NO_x	Nitrogen Oxides		

2.3. Permit Expiration and Renewal

- 2.3.1. Permit duration. This permit is issued for a fixed term of five (5) years and shall expire on the date specified on the cover of this permit, except as provided in 45CSR§30-6.3.b. and 45CSR§30-6.3.c.
[45CSR§30-5.1.b.]
- 2.3.2. A permit renewal application is timely if it is submitted at least six (6) months prior to the date of permit expiration.
[45CSR§30-4.1.a.3.]
- 2.3.3. Permit expiration terminates the source's right to operate unless a timely and complete renewal application has been submitted consistent with 45CSR§30-6.2. and 45CSR§30-4.1.a.3.
[45CSR§30-6.3.b.]
- 2.3.4. If the Secretary fails to take final action to deny or approve a timely and complete permit application before the end of the term of the previous permit, the permit shall not expire until the renewal permit has been issued or denied, and any permit shield granted for the permit shall continue in effect during that time.
[45CSR§30-6.3.c.]

2.4. Permit Actions

- 2.4.1. This permit may be modified, revoked, reopened and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or of a notification of planned changes or anticipated noncompliance does not stay any permit condition.
[45CSR§30-5.1.f.3.]

2.5. Reopening for Cause

- 2.5.1. This permit shall be reopened and revised under any of the following circumstances:
 - a. Additional applicable requirements under the Clean Air Act or the Secretary's legislative rules become applicable to a major source with a remaining permit term of three (3) or more years. Such a reopening shall be completed not later than eighteen (18) months after promulgation of the applicable requirement. No such reopening is required if the effective date of the requirement is later than the date on which the permit is due to expire, unless the original permit or any of its terms and conditions has been extended pursuant to 45CSR§30-6.6.a.1.A. or B.
 - b. Additional requirements (including excess emissions requirements) become applicable to an affected source under Title IV of the Clean Air Act (Acid Deposition Control) or other legislative rules of the Secretary. Upon approval by U.S. EPA, excess emissions offset plans shall be incorporated into the permit.
 - c. The Secretary or U.S. EPA determines that the permit contains a material mistake or that inaccurate statements were made in establishing the emissions standards or other terms or conditions of the permit.
 - d. The Secretary or U.S. EPA determines that the permit must be revised or revoked and reissued to assure compliance with the applicable requirements.

[45CSR§30-6.6.a.]

2.6. Administrative Permit Amendments

- 2.6.1. The permittee may request an administrative permit amendment as defined in and according to the procedures specified in 45CSR§30-6.4.
[45CSR§30-6.4.]

2.7. Minor Permit Modifications

- 2.7.1. The permittee may request a minor permit modification as defined in and according to the procedures specified in 45CSR§30-6.5.a.
[45CSR§30-6.5.a.]

2.8. Significant Permit Modification

- 2.8.1. The permittee may request a significant permit modification, in accordance with 45CSR§30-6.5.b., for permit modifications that do not qualify for minor permit modifications or as administrative amendments.
[45CSR§30-6.5.b.]

2.9. Emissions Trading

- 2.9.1. No permit revision shall be required, under any approved economic incentives, marketable permits, emissions trading, and other similar programs or processes for changes that are provided for in the permit and that are in accordance with all applicable requirements.
[45CSR§30-5.1.h.]

2.10. Off-Permit Changes

- 2.10.1. Except as provided below, a facility may make any change in its operations or emissions that is not addressed nor prohibited in its permit and which is not considered to be construction nor modification under any rule promulgated by the Secretary without obtaining an amendment or modification of its permit. Such changes shall be subject to the following requirements and restrictions:
- a. The change must meet all applicable requirements and may not violate any existing permit term or condition.
 - b. The permittee must provide a written notice of the change to the Secretary and to U.S. EPA within two (2) business days following the date of the change. Such written notice shall describe each such change, including the date, any change in emissions, pollutants emitted, and any applicable requirement that would apply as a result of the change.
 - c. The change shall not qualify for the permit shield.
 - d. The permittee shall keep records describing all changes made at the source that result in emissions of regulated air pollutants, but not otherwise regulated under the permit, and the emissions resulting from those changes.
 - e. No permittee may make any change subject to any requirement under Title IV of the Clean Air Act (Acid Deposition Control) pursuant to the provisions of 45CSR§30-5.9.

- f. No permittee may make any changes which would require preconstruction review under any provision of Title I of the Clean Air Act (including 45CSR14 and 45CSR19) pursuant to the provisions of 45CSR§30-5.9.

[45CSR§30-5.9.]

2.11. Operational Flexibility

- 2.11.1. The permittee may make changes within the facility as provided by § 502(b)(10) of the Clean Air Act. Such operational flexibility shall be provided in the permit in conformance with the permit application and applicable requirements. No such changes shall be a modification under any rule or any provision of Title I of the Clean Air Act (including 45CSR14 and 45CSR19) promulgated by the Secretary in accordance with Title I of the Clean Air Act and the change shall not result in a level of emissions exceeding the emissions allowable under the permit.

[45CSR§30-5.8]

- 2.11.2. Before making a change under 45CSR§30-5.8., the permittee shall provide advance written notice to the Secretary and to U.S. EPA, describing the change to be made, the date on which the change will occur, any changes in emissions, and any permit terms and conditions that are affected. The permittee shall thereafter maintain a copy of the notice with the permit, and the Secretary shall place a copy with the permit in the public file. The written notice shall be provided to the Secretary and U.S. EPA at least seven (7) days prior to the date that the change is to be made, except that this period may be shortened or eliminated as necessary for a change that must be implemented more quickly to address unanticipated conditions posing a significant health, safety, or environmental hazard. If less than seven (7) days notice is provided because of a need to respond more quickly to such unanticipated conditions, the permittee shall provide notice to the Secretary and U.S. EPA as soon as possible after learning of the need to make the change.

[45CSR§30-5.8.a.]

- 2.11.3. The permit shield shall not apply to changes made under 45CSR§30-5.8., except those provided for in 45CSR§30-5.8.d. However, the protection of the permit shield will continue to apply to operations and emissions that are not affected by the change, provided that the permittee complies with the terms and conditions of the permit applicable to such operations and emissions. The permit shield may be reinstated for emissions and operations affected by the change:

- a. If subsequent changes cause the facility's operations and emissions to revert to those authorized in the permit and the permittee resumes compliance with the terms and conditions of the permit, or
- b. If the permittee obtains final approval of a significant modification to the permit to incorporate the change in the permit.

[45CSR§30-5.8.c.]

- 2.11.4. "Section 502(b)(10) changes" are changes that contravene an express permit term. Such changes do not include changes that would violate applicable requirements or contravene enforceable permit terms and conditions that are monitoring (including test methods), recordkeeping, reporting, or compliance certification requirements.

[45CSR§30-2.39]

2.12. Reasonably Anticipated Operating Scenarios

2.12.1. The following are terms and conditions for reasonably anticipated operating scenarios identified in this permit.

- a. Contemporaneously with making a change from one operating scenario to another, the permittee shall record in a log at the permitted facility a record of the scenario under which it is operating and to document the change in reports submitted pursuant to the terms of this permit and 45CSR30.
- b. The permit shield shall extend to all terms and conditions under each such operating scenario; and
- c. The terms and conditions of each such alternative scenario shall meet all applicable requirements and the requirements of 45CSR30.

[45CSR§30-5.1.i.]

2.13. Duty to Comply

2.13.1. The permittee must comply with all conditions of this permit. Any permit noncompliance constitutes a violation of the West Virginia Code and the Clean Air Act and is grounds for enforcement action by the Secretary or USEPA; for permit termination, revocation and reissuance, or modification; or for denial of a permit renewal application.

[45CSR§30-5.1.f.1.]

2.14. Inspection and Entry

2.14.1. The permittee shall allow any authorized representative of the Secretary, upon the presentation of credentials and other documents as may be required by law, to perform the following:

- a. At all reasonable times (including all times in which the facility is in operation) enter upon the permittee's premises where a source is located or emissions related activity is conducted, or where records must be kept under the conditions of this permit;
- b. Have access to and copy, at reasonable times, any records that must be kept under the conditions of this permit;
- c. Inspect at reasonable times (including all times in which the facility is in operation) any facilities, equipment (including monitoring and air pollution control equipment), practices, or operations regulated or required under the permit;
- d. Sample or monitor at reasonable times substances or parameters to determine compliance with the permit or applicable requirements or ascertain the amounts and types of air pollutants discharged.

[45CSR§30-5.3.b.]

2.15. Schedule of Compliance

- 2.15.1. For sources subject to a compliance schedule, certified progress reports shall be submitted consistent with the applicable schedule of compliance set forth in this permit and 45CSR§30-4.3.h., but at least every six (6) months, and no greater than once a month, and shall include the following:
- a. Dates for achieving the activities, milestones, or compliance required in the schedule of compliance, and dates when such activities, milestones or compliance were achieved; and
 - b. An explanation of why any dates in the schedule of compliance were not or will not be met, and any preventative or corrective measure adopted.

[45CSR§30-5.3.d.]

2.16. Need to Halt or Reduce Activity not a Defense

- 2.16.1. It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this permit. However, nothing in this paragraph shall be construed as precluding consideration of a need to halt or reduce activity as a mitigating factor in determining penalties for noncompliance if the health, safety, or environmental impacts of halting or reducing operations would be more serious than the impacts of continued operations.

[45CSR§30-5.1.f.2.]

2.17. Emergency

- 2.17.1. An "emergency" means any situation arising from sudden and reasonably unforeseeable events beyond the control of the source, including acts of God, which situation requires immediate corrective action to restore normal operation, and that causes the source to exceed a technology-based emission limitation under the permit, due to unavoidable increases in emissions attributable to the emergency. An emergency shall not include noncompliance to the extent caused by improperly designed equipment, lack of preventative maintenance, careless or improper operation, or operator error.

[45CSR§30-5.7.a.]

- 2.17.2. Effect of any emergency. An emergency constitutes an affirmative defense to an action brought for noncompliance with such technology-based emission limitations if the conditions of 45CSR§30-5.7.c. are met.

[45CSR§30-5.7.b.]

- 2.17.3. The affirmative defense of emergency shall be demonstrated through properly signed, contemporaneous operating logs, or other relevant evidence that:

- a. An emergency occurred and that the permittee can identify the cause(s) of the emergency;
- b. The permitted facility was at the time being properly operated;
- c. During the period of the emergency the permittee took all reasonable steps to minimize levels of emissions that exceeded the emission standards, or other requirements in the permit; and

- d. Subject to the requirements of 45CSR§30-5.1.c.3.C.1, the permittee submitted notice of the emergency to the Secretary within one (1) working day of the time when emission limitations were exceeded due to the emergency and made a request for variance, and as applicable rules provide. This notice, report, and variance request fulfills the requirement of 45CSR§30-5.1.c.3.B. This notice must contain a detailed description of the emergency, any steps taken to mitigate emissions, and corrective actions taken.

[45CSR§30-5.7.c.]

- 2.17.4. In any enforcement proceeding, the permittee seeking to establish the occurrence of an emergency has the burden of proof.

[45CSR§30-5.7.d.]

- 2.17.5. This provision is in addition to any emergency or upset provision contained in any applicable requirement.

[45CSR§30-5.7.e.]

2.18. Federally-Enforceable Requirements

- 2.18.1. All terms and conditions in this permit, including any provisions designed to limit a source's potential to emit and excepting those provisions that are specifically designated in the permit as "State-enforceable only", are enforceable by the Secretary, USEPA, and citizens under the Clean Air Act.

[45CSR§30-5.2.a.]

- 2.18.2. Those provisions specifically designated in the permit as "State-enforceable only" shall become "Federally-enforceable" requirements upon SIP approval by the USEPA.

2.19. Duty to Provide Information

- 2.19.1. The permittee shall furnish to the Secretary within a reasonable time any information the Secretary may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. Upon request, the permittee shall also furnish to the Secretary copies of records required to be kept by the permittee. For information claimed to be confidential, the permittee shall furnish such records to the Secretary along with a claim of confidentiality in accordance with 45CSR31. If confidential information is to be sent to USEPA, the permittee shall directly provide such information to USEPA along with a claim of confidentiality in accordance with 40 C.F.R. Part 2.

[45CSR§30-5.1.f.5.]

2.20. Duty to Supplement and Correct Information

- 2.20.1. Upon becoming aware of a failure to submit any relevant facts or a submittal of incorrect information in any permit application, the permittee shall promptly submit to the Secretary such supplemental facts or corrected information.

[45CSR§30-4.2.]

2.21. Permit Shield

- 2.21.1. Compliance with the conditions of this permit shall be deemed compliance with any applicable requirements as of the date of permit issuance provided that such applicable requirements are included and are specifically

identified in this permit or the Secretary has determined that other requirements specifically identified are not applicable to the source and this permit includes such a determination or a concise summary thereof.

[45CSR§30-5.6.a.]

2.21.2. Nothing in this permit shall alter or affect the following:

- a. The liability of an owner or operator of a source for any violation of applicable requirements prior to or at the time of permit issuance; or
- b. The applicable requirements of the Code of West Virginia and Title IV of the Clean Air Act (Acid Deposition Control), consistent with § 408 (a) of the Clean Air Act.
- c. The authority of the Administrator of U.S. EPA to require information under § 114 of the Clean Air Act or to issue emergency orders under § 303 of the Clean Air Act.

[45CSR§30-5.6.c.]

2.22. Credible Evidence

2.22.1. Nothing in this permit shall alter or affect the ability of any person to establish compliance with, or a violation of, any applicable requirement through the use of credible evidence to the extent authorized by law. Nothing in this permit shall be construed to waive any defenses otherwise available to the permittee including but not limited to any challenge to the credible evidence rule in the context of any future proceeding.

[45CSR§30-5.3.e.3.B. and 45CSR38]

2.23. Severability

2.23.1. The provisions of this permit are severable. If any provision of this permit, or the application of any provision of this permit to any circumstance is held invalid by a court of competent jurisdiction, the remaining permit terms and conditions or their application to other circumstances shall remain in full force and effect.

[45CSR§30-5.1.e.]

2.24. Property Rights

2.24.1. This permit does not convey any property rights of any sort or any exclusive privilege.

[45CSR§30-5.1.f.4]

2.25. Acid Deposition Control

2.25.1. Emissions shall not exceed any allowances that the source lawfully holds under Title IV of the Clean Air Act (Acid Deposition Control) or rules of the Secretary promulgated thereunder.

- a. No permit revision shall be required for increases in emissions that are authorized by allowances acquired pursuant to the acid deposition control program, provided that such increases do not require a permit revision under any other applicable requirement.
- b. No limit shall be placed on the number of allowances held by the source. The source may not, however, use allowances as a defense to noncompliance with any other applicable requirement.

- c. Any such allowance shall be accounted for according to the procedures established in rules promulgated under Title IV of the Clean Air Act.

[45CSR§30-5.1.d.]

- 2.25.2. Where applicable requirements of the Clean Air Act are more stringent than any applicable requirement of regulations promulgated under Title IV of the Clean Air Act (Acid Deposition Control), both provisions shall be incorporated into the permit and shall be enforceable by the Secretary and U. S. EPA.

[45CSR§30-5.1.a.2.]

3.0 Facility-Wide Requirements

3.1 Limitations and Standards

- 3.1.1. **Open burning.** The open burning of refuse by any person is prohibited except as noted in 45CSR§6-3.1. [45CSR§6-3.1; R13-1104, 3.1.1]
- 3.1.2. **Open burning exemptions.** The exemptions listed in 45CSR§6-3.1 are subject to the following stipulation: Upon notification by the Secretary, no person shall cause or allow any form of open burning during existing or predicted periods of atmospheric stagnation. Notification shall be made by such means as the Secretary may deem necessary and feasible. [45CSR§6-3.2; R13-1104, 3.1.2]
- 3.1.3. **Asbestos.** The permittee is responsible for thoroughly inspecting the facility, or part of the facility, prior to commencement of demolition or renovation for the presence of asbestos and complying with 40 C.F.R. § 61.145, 40 C.F.R. § 61.148, and 40 C.F.R. § 61.150. The permittee, owner, or operator must notify the Secretary at least ten (10) working days prior to the commencement of any asbestos removal on the forms prescribed by the Secretary if the permittee is subject to the notification requirements of 40 C.F.R. § 61.145(b)(3)(i). The USEPA, the Division of Waste Management and the Bureau for Public Health - Environmental Health require a copy of this notice to be sent to them. [40 C.F.R. §61.145(b) and 45CSR15; 45CSR13, R13-1104, 3.1.3]
- 3.1.4. **Odor.** No person shall cause, suffer, allow or permit the discharge of air pollutants which cause or contribute to an objectionable odor at any location occupied by the public. [45CSR§4-3.1 State-Enforceable only; 45CSR13, R13-1104, 3.1.4]
- 3.1.5. **Standby plan for reducing emissions.** When requested by the Secretary, the permittee shall prepare standby plans for reducing the emissions of air pollutants in accordance with the objectives set forth in Tables I, II, and III of 45CSR11. [45CSR§11-5.2; 45CSR13, R13-1104, 3.1.6]
- 3.1.6. **Emission inventory.** The permittee is responsible for submitting, on an annual basis, an emission inventory in accordance with the submittal requirements of the Division of Air Quality. [W.Va. Code § 22-5-4(a)(14)]
- 3.1.7. **Ozone-depleting substances.** For those facilities performing maintenance, service, repair or disposal of appliances, the permittee shall comply with the standards for recycling and emissions reduction pursuant to 40 C.F.R. Part 82, Subpart F, except as provided for Motor Vehicle Air Conditioners (MVACs) in Subpart B:
- a. Persons opening appliances for maintenance, service, repair, or disposal must comply with the prohibitions and required practices pursuant to 40 C.F.R. §§ 82.154 and 82.156.
 - b. Equipment used during the maintenance, service, repair, or disposal of appliances must comply with the standards for recycling and recovery equipment pursuant to 40 C.F.R. § 82.158.
 - c. Persons performing maintenance, service, repair, or disposal of appliances must be certified by an approved technician certification program pursuant to 40 C.F.R. § 82.161.

[40 C.F.R. 82, Subpart F]

- 3.1.8. **Risk Management Plan.** Should this stationary source, as defined in 40 C.F.R. § 68.3, become subject to Part 68, then the owner or operator shall submit a risk management plan (RMP) by the date specified in 40 C.F.R. § 68.10 and shall certify compliance with the requirements of Part 68 as part of the annual compliance certification as required by 40 C.F.R. Part 70 or 71.
[40 C.F.R. 68]
- 3.1.9. No person shall cause, suffer, allow or permit the emission into the open air from any source operation an in-stack sulfur dioxide concentration exceeding 2,000 parts per million by volume from existing source operations, except as provided in 45CSR§10-4.1.a through 45CSR§10-4.1.e.
[45CSR§10-4.1] [DEHY01, DEHY]
- 3.1.10. No person shall cause, suffer, allow or permit the combustion of any refinery process gas stream or any other process gas stream that contains hydrogen sulfide in a concentration greater than 50 grains per 100 cubic feet of gas except in the case of a person operating in compliance with an emission control and mitigation plan approved by the Director and U. S. EPA. In certain cases very small units may be considered exempt from this requirement if, in the opinion of the Director, compliance would be economically unreasonable and if the contribution of the unit to the surrounding air quality could be considered negligible.
[45CSR§10-5.1] [DEHY01, DEHY]
- 3.1.11. No person shall cause, suffer, allow or permit fugitive particulate matter to be discharged beyond the boundary lines of the property on which the discharge originates or at any public or residential location, which causes or contributes to statutory air pollution.
[45CSR§17-3.1]
- 3.1.12. **Minor Source of Hazardous Air Pollutants (HAP).** HAP emissions from the facility shall be less than 10 tons/year of any single HAP and 25 tons/year of any combination of HAPs. Compliance with this Section shall ensure that the facility is a minor HAP source.
[45CSR13, R13-1104, 4.1.2] [DEHY01, RBR01]
- ~~3.1.12. When emissions on an annual basis of one or more of the greenhouse gases listed below are greater than the *de minimis* amounts listed below, all greenhouse gases emitted above the *de minimis* amounts shall be reported to the Secretary under 45CSR§42-4. (see Section 3.5.):~~

Greenhouse Gas Compound	tons/year
carbon dioxide	10,000
methane	476
nitrous oxide	32.6
hydrofluorocarbons	0.855
perfluorocarbons	1.09
sulfur hexafluoride	0.42

~~[45CSR§42-3.1., State-Enforceable only.]~~

3.2. Monitoring Requirements

- 3.2.1. Visual emission checks of each emission point specified shall be conducted monthly. If during these checks or at any other time visible emissions are observed at any emission point, compliance shall be determined by conducting tests in accordance with Method 9 of 40 C.F.R. 60, Appendix A (July 1, 1994). Records shall be

maintained on site or at a reasonably available location stating the date and time of each visible emission check and whether visible emissions were observed. Visible emission checks shall not be required during start-ups, shut-downs and malfunctions.

[45CSR§30-5.1.c.][DEHY]

- 3.2.2. At a minimum of once per year, sample and analyze the inlet gas stream to the station utilizing gas chromatography for the presence of Sulfur. Proof of compliance with the 2000 ppm_v limit will be considered demonstrated if the gas chromatograph shows a total sulfur content of 3.2379 grains/100ft³ or less for the dehydration unit. Records shall be maintained on site or at a reasonably available location for a period of no less than five (5) years stating the date and time of analysis and the sulfur content of the gas sampled.

[45CSR§30-5.1.c.] [DEHY]

- 3.2.3. At a minimum of once per year, sample and analyze the inlet gas stream utilizing gas chromatography for the presence of H₂S. Proof of compliance with the 50 grains/100ft³ limit will be considered demonstrated if the gas chromatograph shows a total H₂S content of 0.3427 grains/100ft³ or less for the dehydration unit. Records shall be maintained on site or at a reasonably available location stating the date of analysis and the hydrogen sulfide content of the gas sampled.

[45CSR§30-5.1.c.] [DEHY]

3.3. Testing Requirements

- 3.3.1. **Stack testing.** As per provisions set forth in this permit or as otherwise required by the Secretary, in accordance with the West Virginia Code, underlying regulations, permits and orders, the permittee shall conduct test(s) to determine compliance with the emission limitations set forth in this permit and/or established or set forth in underlying documents. The Secretary, or his duly authorized representative, may at his option witness or conduct such test(s). Should the Secretary exercise his option to conduct such test(s), the operator shall provide all necessary sampling connections and sampling ports to be located in such manner as the Secretary may require, power for test equipment and the required safety equipment, such as scaffolding, railings and ladders, to comply with generally accepted good safety practices. Such tests shall be conducted in accordance with the methods and procedures set forth in this permit or as otherwise approved or specified by the Secretary in accordance with the following:

- a. The Secretary may on a source-specific basis approve or specify additional testing or alternative testing to the test methods specified in the permit for demonstrating compliance with 40 C.F.R. Parts 60, 61, and 63, if applicable, in accordance with the Secretary's delegated authority and any established equivalency determination methods which are applicable.
- b. The Secretary may on a source-specific basis approve or specify additional testing or alternative testing to the test methods specified in the permit for demonstrating compliance with applicable requirements which do not involve federal delegation. In specifying or approving such alternative testing to the test methods, the Secretary, to the extent possible, shall utilize the same equivalency criteria as would be used in approving such changes under Section 3.3.1.a. of this permit.
- c. All periodic tests to determine mass emission limits from or air pollutant concentrations in discharge stacks and such other tests as specified in this permit shall be conducted in accordance with an approved test protocol. Unless previously approved, such protocols shall be submitted to the Secretary in writing at least thirty (30) days prior to any testing and shall contain the information set forth by the Secretary. In addition, the permittee shall notify the Secretary at least fifteen (15) days prior to any testing so the Secretary may

have the opportunity to observe such tests. This notification shall include the actual date and time during which the test will be conducted and, if appropriate, verification that the tests will fully conform to a referenced protocol previously approved by the Secretary.

- d. The permittee shall submit a report of the results of the stack test within 60 days of completion of the test. The test report shall provide the information necessary to document the objectives of the test and to determine whether proper procedures were used to accomplish these objectives. The report shall include the following: the certification described in paragraph 3.5.1; a statement of compliance status, also signed by a responsible official; and, a summary of conditions which form the basis for the compliance status evaluation. The summary of conditions shall include the following:
1. The permit or rule evaluated, with the citation number and language.
 2. The result of the test for each permit or rule condition.
 3. A statement of compliance or non-compliance with each permit or rule condition.

[WV Code §§ 22-5-4(a)(~~14~~-15) and 45CSR13]

3.4. Recordkeeping Requirements

- 3.4.1. **Monitoring information.** The permittee shall keep records of monitoring information that include the following:
- a. The date, place as defined in this permit and time of sampling or measurements;
 - b. The date(s) analyses were performed;
 - c. The company or entity that performed the analyses;
 - d. The analytical techniques or methods used;
 - e. The results of the analyses; and
 - f. The operating conditions existing at the time of sampling or measurement.

[45CSR§30-5.1.c.2.A; 45CSR13, R13-1104, 4.1.1]

- 3.4.2. **Retention of records.** The permittee shall retain records of all required monitoring data and support information for a period of at least five (5) years from the date of monitoring sample, measurement, report, application, or record creation date. Support information includes all calibration and maintenance records and all original strip-chart recordings for continuous monitoring instrumentation, and copies of all reports required by the permit. Where appropriate, records may be maintained in computerized form in lieu of the above records.

[45CSR§30-5.1.c.2.B; 45CSR13, R13-1104, 3.4.1]

- 3.4.3. **Odors.** For the purposes of 45CSR4, the permittee shall maintain a record of all odor complaints received, any

investigation performed in response to such a complaint, and any responsive action(s) taken.

[45CSR§30-5.1.c. State-Enforceable only.]

3.5. Reporting Requirements

- 3.5.1. **Responsible official.** Any application form, report, or compliance certification required by this permit to be submitted to the DAQ and/or USEPA shall contain a certification by the responsible official that states that, based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate and complete.

[45CSR§§30-4.4. and 5.1.c.3.D.]

- 3.5.2. A permittee may request confidential treatment for the submission of reporting required under 45CSR§30-5.1.c.3. pursuant to the limitations and procedures of W.Va. Code § 22-5-10 and 45CSR31.

[45CSR§30-5.1.c.3.E.]

- 3.5.3. Except for the electronic submittal of the annual certification to the USEPA as required in 3.5.5 below, all notices, requests, demands, submissions and other communications required or permitted to be made to the Secretary of DEP and/or USEPA shall be made in writing and shall be deemed to have been duly given when delivered by hand, mailed first class or by private carrier with postage prepaid to the address(es) set forth below or to such other person or address as the Secretary of the Department of Environmental Protection may designate:

If to the DAQ:

Director
WVDEP
Division of Air Quality
601 57th Street SE
Charleston, WV 25304

Phone: 304/926-0475
FAX: 304/926-0478

If to the US EPA:

Associate Director
Office of Enforcement and Permits Review
(3AP12)
U. S. Environmental Protection Agency
Region III
1650 Arch Street
Philadelphia, PA 19103-2029

- 3.5.4. **Certified emissions statement.** The permittee shall submit a certified emissions statement and pay fees on an annual basis in accordance with the submittal requirements of the Division of Air Quality.

[45CSR§30-8.]

- 3.5.5. **Compliance certification.** The permittee shall certify compliance with the conditions of this permit on the forms provided by the DAQ. In addition to the annual compliance certification, the permittee may be required to submit certifications more frequently under an applicable requirement of this permit. The annual certification shall be submitted to the DAQ and USEPA on or before March 15 of each year, and shall certify compliance for the period ending December 31. The annual certification to the USEPA shall be submitted in electronic format only. It shall be submitted by e-mail to the following address: R3_APD_Permits@epa.gov. The permittee shall maintain a copy of the certification on site for five (5) years from submittal of the certification.

[45CSR§30-5.3.e.]

- 3.5.6. **Semi-annual monitoring reports.** The permittee shall submit reports of any required monitoring on or before September 15 for the reporting period January 1 to June 30 and on or before March 15 for the reporting period

July 1 to December 31. All instances of deviation from permit requirements must be clearly identified in such reports. All required reports must be certified by a responsible official consistent with 45CSR§30-4.4.
[45CSR§30-5.1.c.3.A.]

3.5.7. **Emergencies.** For reporting emergency situations, refer to Section 2.17 of this permit.

3.5.8. **Deviations.**

- a. In addition to monitoring reports required by this permit, the permittee shall promptly submit supplemental reports and notices in accordance with the following:
 4. Any deviation resulting from an emergency or upset condition, as defined in 45CSR§30-5.7., shall be reported by telephone or telefax within one (1) working day of the date on which the permittee becomes aware of the deviation, if the permittee desires to assert the affirmative defense in accordance with 45CSR§30-5.7. A written report of such deviation, which shall include the probable cause of such deviations, and any corrective actions or preventative measures taken, shall be submitted and certified by a responsible official within ten (10) days of the deviation.
 5. Any deviation that poses an imminent and substantial danger to public health, safety, or the environment shall be reported to the Secretary immediately by telephone or telefax. A written report of such deviation, which shall include the probable cause of such deviation, and any corrective actions or preventative measures taken, shall be submitted by the responsible official within ten (10) days of the deviation.
 6. Deviations for which more frequent reporting is required under this permit shall be reported on the more frequent basis.
 7. All reports of deviations shall identify the probable cause of the deviation and any corrective actions or preventative measures taken.

[45CSR§30-5.1.c.3.C.]

- b. The permittee shall, in the reporting of deviations from permit requirements, including those attributable to upset conditions as defined in this permit, report the probable cause of such deviations and any corrective actions or preventive measures taken in accordance with any rules of the Secretary.

[45CSR§30-5.1.c.3.B.]

3.5.9. **New applicable requirements.** If any applicable requirement is promulgated during the term of this permit, the permittee will meet such requirements on a timely basis, or in accordance with a more detailed schedule if required by the applicable requirement.

[45CSR§30-4.3.h.1.B.]

~~3.5.10. **Greenhouse Gas Reporting Requirements.** When applicable, as determined in permit section 3.1., greenhouse gas emissions shall be reported pursuant to 45CSR§42-4. as follows:~~

- ~~a. In accordance with a reporting cycle provided by the Secretary, affected sources shall report to the Secretary the quantity of all greenhouse gases emitted above *de minimis* amounts in the years specified by the Secretary.~~

~~[45CSR§42-4.1., State Enforceable only.]~~

~~b. Affected sources shall only be required to report annual quantities of anthropogenic non-mobile source greenhouse gases emitted at the stationary source, and shall not be required to report biogenic emissions of greenhouse gases.~~

~~[45CSR§42-4.2., State Enforceable only.]~~

~~c. Reports of greenhouse gas emissions submitted to the Secretary under 45CSR§42-4. shall be signed by a responsible official and shall include the following certification statement: "I, the undersigned, hereby certify that the data transmitted to the West Virginia Department of Environmental Protection is true, accurate, and complete, based upon information and belief formed after reasonable inquiry."~~

~~[45CSR§42-4.5., State Enforceable only.]~~

3.6. Compliance Plan

3.6.1. N/A

3.7. Permit Shield

3.7.1. The permittee is hereby granted a permit shield in accordance with 45CSR§30-5.6. The permit shield applies provided the permittee operates in accordance with the information contained within this permit.

3.7.2. The following requirements specifically identified are not applicable to the source based on the determinations set forth below. The permit shield shall apply to the following requirements provided the conditions of the determinations are met.

a. N/A

3.8. Emergency Operating Scenario

3.8.1. For emergency situations which interrupt the critical supply of natural gas to the public, and which pose a life threatening circumstance to the customer, the permittee is allowed to temporarily replace failed engine(s) as long as all of the following conditions are met:

- a. The replacement engine(s) is only allowed to operate until repair of the failed engine(s) is complete, but under no circumstance may the replacement engine(s) operate in excess of sixty (60) days;
- b. Both the replacement engine(s) and the repaired failed engine(s) shall not operate at the same time with the exception of any necessary testing of the repaired engine(s) and this testing may not exceed five (5) hours;
- c. Potential hourly emissions from the replacement engine(s) are less than or equal to the potential hourly emissions from the engine(s) being replaced;
- d. Credible performance emission test data verifying the emission rates associated with the operation of the substitute engine shall be submitted to the Director within five (5) days;
- e. The permittee must provide written notification to the Director within five (5) days of the replacement. This notification must contain:
 - i. Information to support the claim of life threatening circumstances to justify applicability of this emergency provision;

- ii. Identification of the engine(s) being temporarily replaced;
- iii. The design parameters of the replacement engine(s) including, but not limited to, the design horsepower and emission factors;
- iv. Projected duration of the replacement engine(s); and
- v. The appropriate certification by a responsible official.

[45CSR§30-12.7]

4.0 Source-Specific Requirements [RBR01]

4.1. Limitations and Standards

- 4.1.1. No person shall cause, suffer, allow or permit emission of smoke and/or particulate matter into the open air from any fuel burning unit which is greater than ten (10) percent opacity based on a six minute block average.
[45CSR§2-3.1; 45CSR13, R13-1104, 5.1.1]
- 4.1.2. Compliance with the visible emission requirements of 45CSR§2-3.1 shall be determined in accordance with 40 C.F.R. Part 60, Appendix A, Method 9 or by using measurements from continuous opacity monitoring systems approved by the Director. The Director may require the installation, calibration, maintenance and operation of continuous opacity monitoring systems and may establish policies for the evaluation of continuous opacity monitoring results and the determination of compliance with the visible emission requirements of 45CSR§2-3.1. Continuous opacity monitors shall not be required on fuel burning units which employ wet scrubbing systems for emission control.
[45CSR§2-3.2 and 45CSR13, R13-1104, 5.1.2]
- 4.1.3. Maximum Design Heat Input. The maximum design heat input for the Glycol Reboiler (RBR01) shall not exceed 1.0 mmBTU/hr.
[45CSR13, R13-1104, 5.1.3]
- 4.1.4. The quantity of natural gas that shall be consumed in the 1.0 MMBtu/hr Glycol Reboiler (RBR01) shall not exceed 960 cubic feet per hour or 8.41×10^6 cubic feet per year.
[45CSR13, R13-1104, 5.1.4.]
- 4.1.5. Maximum emissions from Glycol Reboiler (RBR01) shall not exceed the following limits:

Emission Point ID	Pollutant	Maximum Emission Rate	
		Lb/hr	Tons/Yr
Dehydration Unit Reboiler - RBR01	CO	0.08	0.35
	NOx	0.10	0.42

[45CSR13, R13-1104, 5.1.5]

4.2. Monitoring Requirements

- 4.2.1. At such reasonable times as the Secretary may designate, the permittee shall conduct Method 9 emission observations for the purpose of demonstrating compliance with Section 4.1.1. Method 9 shall be conducted in accordance with 40 CFR 60 Appendix A.
[45CSR13, R13-1104, 5.2.1]
- 4.2.2. The permittee shall monitor the natural gas consumed in the Glycol Reboiler (RBR01) on a monthly basis.
[45CSR13, R13-1104, 5.2.2]

4.3. Testing Requirements

- 4.3.1. N/A

4.4. Recordkeeping Requirements

- 4.4.1. To demonstrate compliance with section 4.1.4 and 4.1.5, the permittee shall maintain records of the amount of natural gas consumed in the Glycol Reboiler (RBR01). Said records shall be maintained on site or in a readily accessible off-site location maintained by the permittee for a period of five (5) years. Said records shall be readily available to the Director of the Division of Air Quality or his/her duly authorized representative for expeditious inspection and review. Any records submitted to the agency pursuant to a requirement of this permit or upon request by the Director shall be certified by a responsible official.
[45CSR13, R13-1104, 5.3.1]

4.5. Reporting Requirements

- 4.5.1. N/A

4.6. Compliance Plan

- 4.6.1. N/A

5.0 Source-Specific Hazardous Air Pollutant Requirements (Natural Gas Dehydration Units (DEHY01) ~~Not Subject to MACT Standards~~ and being controlled by a Flare Control Device (F1)) [DEHY, DEHY01]

5.1. Limitations and Standards

5.1.1. **Maximum Throughput Limitation.** The maximum wet natural gas throughput to the glycol dehydration unit (DEHY01) shall not exceed 18 mmcf/day. Compliance with the Maximum Throughput Limitation shall be determined using a twelve month rolling total. A twelve month rolling total shall mean the sum of the monthly throughput at any given time during the previous twelve consecutive calendar months.
[45CSR13, R13-1104, 6.1.1]

5.1.2. Maximum emissions from the Tulpro flare (F1) shall not exceed the following limits:

Pollutant	Maximum Emission Rate	
	Lb/hr	Tons/Yr
VOC	11.93	52.25
Benzene	0.07	0.28
Toluene	0.26	1.15
Ethylbenzene	0.16	0.7
Xylene	1.71	7.47
n-Hexane	0.01	0.02

[45CSR13, R13-1104, 6.1.2][DEHY01]

5.1.3. For purposes of determining potential HAP emissions at transmission and storage facilities to comply with the requirements in Section 3.1.12, the methods specified in 40 CFR 63, Subpart HHH shall be used. For purposes of determining potential HAP emissions at production-related facilities, the methods specified in 40 CFR 63, Subpart HH (i.e. excluding compressor engines from HAP PTE) shall be used.
[45CSR13, R13-1104, 6.1.3]

5.1.4. Flare (F1) subject to this section shall be designed and operated in accordance with the following:

- Flare (F1) shall be non-assisted.
- Flare (F1) shall be designed for and operated with no visible emissions, except for periods not to exceed a total of 5 minutes during any 2 consecutive hours.
- Flare (F1) shall be operated, with a flame present at all times whenever emissions may be vented to them, except during SSM (Startup, Shutdown, Malfunctions) events.
- A flare shall be used only where the net heating value of the gas being combusted is 11.2 MJ/scm (300 Btu/scf) or greater if the flare is steam-assisted or air-assisted; or where the net heating value of the gas being combusted is 7.45 MJ/scm (200 Btu/scf) or greater if the flares is non-assisted. The net heating value of the gas being combusted in a flare shall be calculated using the following equation:

$$H_T = K \sum_{i=1}^n C_i H_i$$

Where:

H_T =Net heating value of the sample, MJ/scm; where the net enthalpy per mole of off gas is based on combustion at 25 °C and 760 mm Hg, but the standard temperature for determining the volume corresponding to one mole is 20 °C.

K =Constant=

$$1.740 \times 10^{-7} \left(\frac{1}{ppmv} \right) \left(\frac{g\text{-mole}}{scm} \right) \left(\frac{MJ}{kcal} \right)$$

where the standard temperature for (g-mole/scm) is 20 °C.

C_i =Concentration of sample component i in ppmv on a wet basis, which may be measured for organics by Test Method 18, but is not required to be measured using Method 18 (unless designated by the Director).

H_i =Net heat of combustion of sample component i, kcal/g-mole at 25 °C and 760 mm Hg. The heats of combustion may be determined using ASTM D2382-76 or 88 or D4809-95 if published values are not available or cannot be calculated.

n =Number of sample components.

- e. Steam-assisted and nonassisted flares shall be designed for and operated with an exit velocity less than 18.3 m/sec (60 ft/sec), except as provided by 5.1.4.f and 5.1.4.g of this section. The actual exit velocity of a flare shall be determined by dividing by the volumetric flow rate of gas being combusted (in units of emission standard temperature and pressure), by the unobstructed (free) cross-sectional area of the flare tip, which may be determined by Test Method 2, 2A, 2C, or 2D in appendix A to 40 CFR part 60, as appropriate, but is not required to be determined using these Methods (unless designated by the Director).
- f. Steam-assisted and nonassisted flares designed for and operated with an exit velocity, as determined by the method specified in 5.1.4.e. of this section, equal to or greater than 18.3 m/sec (60 ft/sec) but less than 122 m/sec (400 ft/sec), are allowed if the net heating value of the gas being combusted is greater than 37.3 MJ/scm (1,000 Btu/scf).
- g. Steam-assisted and nonassisted flares designed for and operated with an exit velocity, as determined by the method specified in 5.1.4.e. of this section, less than the velocity V_{max} , as determined by the calculation specified in this paragraph, but less than 122 m/sec (400 ft/sec) are allowed. The maximum permitted velocity, V_{max} , for flares complying with this paragraph shall be determined by the following equation:

$$\text{Log}_{10}(V_{max})=(H_T+28.8)/31.7$$

Where:

V_{max} =Maximum permitted velocity, m/sec.

28.8=Constant.

31.7=Constant.

H_T =The net heating value as determined in 5.1.4.d of this section

[45CSR13, R13-1104, 6.1.4]

- 5.1.5. The permittee is not required to conduct a flare compliance assessment for concentration of sample (i.e. Method 18) and tip velocity (i.e. Method 2) until such time as the Director requests a flare compliance assessment to be conducted in accordance with section 5.3.2, but the permittee is required to conduct a flare design evaluation in accordance with section 5.4.2. Alternatively, the permittee may elect to demonstrate compliance with the flare

design criteria requirements of section 5.1.4 by complying with the compliance assessment testing requirements of section 5.3.2.

[45CSR13, R13-1104, 6.1.5]

- 5.1.6. Visible Particulate Matter emissions from the flare (F1) shall not exceed twenty (20%) percent opacity.

[45CSR§6-4.3 and 45CSR13, R13-1104, 6.1.6][DEHY]

- 5.1.7. The provisions of permit condition 5.1.6 shall not apply to smoke which is less than forty (40%) percent opacity, for a period or periods aggregating no more than eight (8) minutes per start-up.

[45CSR§6-4.4 and 45CSR13, R13-1104, 6.1.7]

- 5.1.8. The flare (F1) including all associated equipment and grounds, shall be designed, operated and maintained so as to prevent the emission of objectionable odors.

[45CSR§6-4.6 and 45CSR13, R13-1104, 6.1.8][DEHY]

- 5.1.9. No person shall cause, suffer, allow or permit particulate matter to be discharged from any incinerator into the open air in excess of the quantity determined by use of the following formula:

Emissions (lb/hr) = F x Incinerator Capacity (tons/hr)

Where, the factor, F, is as indicated in Table I below:

Table I: Factor, F, for Determining Maximum Allowable Particulate Emissions

Incinerator Capacity	Factor F
A. Less than 15,000 lbs/hr	5.43
B. 15,000 lbs/hr or greater	2.72

[45CSR§6-4.1][DEHY]

- 5.1.10. **Operation and Maintenance of Air Pollution Control Equipment.** The permittee shall, to the extent practicable, install, maintain, and operate all pollution control equipment listed in Section 1.0 and associated monitoring equipment in a manner consistent with safety and good air pollution control practices for minimizing emissions, or comply with any more stringent limits set forth in this permit or as set forth by any State rule, Federal regulation, or alternative control plan approved by the Secretary.

[45CSR13, R13-1104, 4.1.3]

5.1.11. 40 C.F.R. §63.764 General standards (note the following section numbers match those of 40 C.F.R. §63.764)

(a) Table 2 of the Part 63 Subpart HH specifies the provisions of subpart A (General Provisions) of Part 63 that apply and those that do not apply to owners and operators of affected sources subject to this subpart.

(b) All reports required under this subpart shall be sent to the Administrator at the appropriate address listed in 40 C.F.R. §63.13. Reports may be submitted on electronic media.

(d) Except as specified in paragraph (e)(1) of this requirement, the owner or operator of an affected source located at an existing or new area source of HAP emissions shall comply with the applicable standards specified in paragraph (d) of 40 C.F.R. §63.764.

(e) Exemptions. (1) The owner or operator is exempt from the requirements of paragraph (d) of 40 C.F.R. §63.764 if the criteria listed in paragraph (e)(1)(ii) of this section are met, except that the records of the determination of these criteria must be maintained as required in 40 C.F.R. §63.774(d)(1).

(ii) The actual average emissions of benzene from the glycol dehydration unit process vent to the atmosphere are less than 0.90 megagram per year (1 ton/yr), as determined by the procedures specified in 40 C.F.R. §63.772(b)(2).

[40CFR§63.764]

5.2. Monitoring Requirements

5.2.1. In order to demonstrate compliance with the requirements of 5.1.4.c, the permittee shall monitor the presence or absence of a flare pilot flame using a thermocouple or any other equivalent device, except during SSM events. **[45CSR13, R13-1104, 6.2.1; 40 C.F.R. § 64.3(a)]**

5.2.2. The permittee shall monitor the throughput of wet natural gas fed to the dehydration system on a monthly basis for the glycol dehydration unit (DEHY01). **[45CSR13, R13-1104, 6.2.2]**

5.2.3. **Commencement of operation.** The permittee shall conduct the monitoring required under 40 CFR Part 64 upon issuance of this permit that includes such monitoring, or by the initial start-up date of the flare F1 that requires such monitoring, whichever is later. **[40 CFR §§ 64.7(a) and 64.6(d); 45CSR§30-5.1.c.]**

5.2.4. **Proper Maintenance** – At all times, the permittee shall maintain the monitoring, including but not limited to, maintaining necessary parts for routine repairs of the monitoring equipment. **[40 CFR § 64.7(b); 45CSR§30-5.1.c.]**

5.2.5. **Continued Operation** – Except for, as applicable, monitoring malfunctions, associated repairs, and required quality assurance or control activities (including, as applicable, calibration checks and required zero and span adjustments), the permittee shall conduct all monitoring in continuous operation at all times that the pollutant-specific emissions unit is operating. Data recorded during monitoring malfunctions, associated repairs, and required quality assurance or control activities shall not be used for purposes of 40 CFR Part 64, including data averages and calculations, or fulfilling a minimum data availability requirement, if applicable. The owner or operator shall use all the data collected during all other periods in assessing the operation of the control device and associated control system. A monitoring malfunction is any sudden, infrequent, not reasonably preventable failure of the monitoring to provide valid data. Monitoring failures that are caused in part by poor maintenance or careless operation are not malfunctions. **[40 CFR § 64.7(c); 45CSR§30-5.1.c.]**

5.2.6. **Documentation of Need for Improved Monitoring** – After approval of monitoring under 40 CFR Part 64, if the permittee identifies a failure to achieve compliance with an emission limitation or standard for which the approved monitoring did not provide an indication of an excursion or exceedance while providing valid data, or the results of compliance or performance testing document a need to modify the existing indicator ranges or designated conditions, the permittee shall promptly notify the Director and, if necessary, submit a proposed modification to the permit to address the necessary monitoring changes. Such a modification may include, but is not limited to, reestablishing indicator ranges or designated conditions, modifying the frequency of conducting

monitoring and collecting data, or the monitoring of additional parameters.

[40 CFR § 64.7(e); 45CSR§30-5.1.c.]

- 5.2.7. **Quality Improvement Plan (QIP)** – Based on the results of a determination made under 40 CFR §64.7(d)(2) (permit condition 5.4.9.b), the Administrator or the Director may require the permittee to develop and implement a QIP. If a QIP is required, then it shall be developed, implemented, and modified as required according to 40 CFR §§ 64.8(b) through (e). Refer to permit condition 5.5.4.b.3. for the reporting required when a QIP is implemented.

[40 CFR § 64.8; 45CSR§30-5.1.c.]

- 5.2.8. **Excursions** – The dehydration unit is designed to “shutdown” if the absence of a flame is detected after automatic reignition is unsuccessful. Therefore an excursion will occur if the dehydration unit is not shutdown when the absence of a flame is detected after unsuccessful reignition.

[40 CFR § 64.6(c)(2); 45CSR§30-5.1.c.]

5.3. Testing Requirements

- 5.3.1. In order to demonstrate compliance with the flare opacity requirements of 5.1.4.b the permittee shall conduct a Method 22 opacity test for at least two hours. This test shall demonstrate no visible emissions are observed for more than a total of 5 minutes during any 2 consecutive hour period using 40CFR60 Appendix A Method 22. The permittee shall conduct this test within one (1) year of permit issuance or initial startup whichever is later. The visible emission checks shall determine the presence or absence of visible emissions. At a minimum, the observer must be trained and knowledgeable regarding the effects of background contrast, ambient lighting, observer position relative to lighting, wind, and the presence of uncombined water (condensing water vapor) on the visibility of emissions. This training may be obtained from written materials found in the References 1 and 2 from 40 CFR part 60, appendix A, Method 22 or from the lecture portion of 40 CFR part 60, appendix A, Method 9 certification course.

[45CSR13, R13-1104, 6.3.1.]

- 5.3.2. The Director may require the permittee to conduct a flare compliance assessment to demonstrate compliance with section 5.1.4. This compliance assessment testing shall be conducted in accordance with Test Method 18 for organics and Test Method 2, 2A, 2C, or 2D in appendix A to 40 CFR part 60, as appropriate, or other equivalent testing approved in writing by the Director. Also, Test Method 18 may require the permittee to conduct Test Method 4 in conjunction with Test Method 18.

[45CSR13, R13-1104, 6.3.2]

- 5.3.3. In order to demonstrate compliance with 5.1.3, upon request of the Director, the permittee shall demonstrate compliance with the HAP emissions thresholds using GRI-GlyCalc Version 3.0 or higher. The permittee shall sample in accordance with the Gas Processor Association GPA Methods 2166 and analyze the samples utilizing the extended GPA Method 2286 as specified in the GRI-GLYCalc V4 Technical Reference User Manual and Handbook.

[45CSR13, R13-1104, 6.3.3.]

- 5.3.4. The following testing and compliance provisions of Part 63 Subpart HH National Emission Standards for Hazardous Air Pollutants From Oil and Natural Gas Production Facilities are applicable to the facility:

§63.772 Test methods, compliance procedures, and compliance demonstrations.

(b) Determination of glycol dehydration unit flowrate or benzene emissions. The procedures of this paragraph shall be used by an owner or operator to determine glycol dehydration unit natural gas flowrate or benzene emissions to meet the criteria for an exemption from control requirements under §63.764(e)(1) (requirement 5.1.11.).

(2) The determination of actual average benzene emissions from a glycol dehydration unit shall be made using the procedures of paragraph (b)(2)(i) of this requirement. Emissions shall be determined either uncontrolled, or with federally enforceable controls in place.

(i) The owner or operator shall determine actual average benzene emissions using the model GRI-GLYCalc™, Version 3.0 or higher, and the procedures presented in the associated GRI-GLYCalc™ Technical Reference Manual. Inputs to the model shall be representative of actual operating conditions of the glycol dehydration unit and may be determined using the procedures documented in the Gas Research Institute (GRI) report entitled “Atmospheric Rich/Lean Method for Determining Glycol Dehydrator Emissions” (CGR-95/0368.1); or

The permittee shall determine an average mass rate of benzene emissions in kilograms per hour through direct measurement using the methods set forth in 40 CFR 63.772(b)(2)(ii). Annual emissions in kilograms per year shall be determined by multiplying the mass rate by the number of hours the unit is operated per year. This result shall be converted to megagrams per year.

[40CFR§63.772 (b)(2)(i)-(ii)]

5.4. Recordkeeping Requirements

- 5.4.1. For the purpose of demonstrating compliance with section 5.1.4.c and 5.2.1, the permittee shall maintain records of the times and duration of all periods which the pilot flame was absent.
[45CSR13, R13-1104, 6.4.1]
- 5.4.2. For the purpose of demonstrating compliance with section 5.1.4 and 5.3.2, the permittee shall maintain a record of the flare design evaluation. The flare design evaluation shall include, net heat value calculations, exit (tip) velocity calculations, and all supporting concentration calculations and other related information requested by the Director.
[45CSR13, R13-1104, 6.4.2]
- 5.4.3. For the purpose of demonstrating compliance with the requirements set forth in sections 5.1.4 and 5.3.3., the permittee shall maintain records of testing conducted in accordance with 5.3.3.
[45CSR13, R13-1104, 6.4.3]
- 5.4.4. The permittee shall document and maintain the corresponding records specified by the on-going monitoring requirements of 5.2 and testing requirements of 5.3.
45CSR13, R13-1104, 6.4.4]
- 5.4.5. For the purpose of demonstrating compliance with section 5.1.4.b, the permittee shall maintain records of the visible emission opacity tests conducted per Section 5.3.1.
[45CSR13, R13-1104, 6.4.5.]
- 5.4.6. The permittee shall maintain a monthly record of the wet natural gas throughput through the dehydration system to demonstrate compliance with section 5.1.1 of this permit. Said records shall be maintained for a period of five (5) years on site or in a readily accessible off-site location maintained by the permittee. Said records shall be readily available to the Director of the Division of Air Quality or his/her duly authorized representative for expeditious inspection and review. Any records submitted to the agency pursuant to a requirement of this

permit or upon request by the Director shall be certified by a responsible official.
[45CSR13, R13-1104, 6.4.6]

- 5.4.7. All records required under Section 5.4 shall be maintained on site or in a readily accessible off-site location maintained by the permittee for a period of five (5) years. Said records shall be readily available to the Director of the Division of Air Quality or his/her duly authorized representative for expeditious inspection and review. Any records submitted to the agency pursuant to a requirement of this permit or upon request by the Director shall be certified by a responsible official.
[45CSR13, R13-1104, 6.4.7]

- 5.4.8. **Record of Malfunctions of Air Pollution Control Equipment.** For all air pollution control equipment listed in Section 1.0, the permittee shall maintain records of the occurrence and duration of any malfunction or operational shutdown of the air pollution control equipment during which excess emissions occur. For each such case, the following information shall be recorded:

- a. The equipment involved.
- b. Steps taken to minimize emissions during the event.
- c. The duration of the event.
- d. The estimated increase in emissions during the event.

For each such case associated with an equipment malfunction, the additional information shall also be recorded:

- e. The cause of the malfunction.
- f. Steps taken to correct the malfunction.
- g. Any changes or modifications to equipment or procedures that would help prevent future recurrences of the malfunction.

[45CSR13, R13-1104, 4.1.4]

- 5.4.9. Response to Excursions or Exceedances

- a. Upon detecting an excursion or exceedance, the permittee shall restore operation of the pollutant-specific emissions unit (including the control device and associated capture system) to its normal or usual manner of operation as expeditiously as practicable in accordance with good air pollution control practices for minimizing emissions. The response shall include minimizing the period of any startup, shutdown or malfunction and taking any necessary corrective actions to restore normal operation and prevent the likely recurrence of the cause of an excursion or exceedance (other than those caused by excused startup or shutdown conditions). Such actions may include initial inspection and evaluation, recording that operations returned to normal without operator action (such as through response by a computerized distribution control system), or any necessary follow-up actions to return operation to within the indicator range, designated condition, or below the applicable emission limitation or standard, as applicable.
- b. Determination of whether the permittee has used acceptable procedures in response to an excursion or exceedance will be based on information available, which may include but is not limited to, monitoring results, review of operation and maintenance procedures and records, and inspection of the control device, associated capture system, and the process.

[40 CFR § 64.7(d); 45CSR§30-5.1.c.]

5.4.10. General recordkeeping requirements for 40 CFR Part 64 (CAM)

The permittee shall comply with the recordkeeping requirements specified in permit conditions 3.4.1. and 3.4.2. The permittee shall maintain records of monitoring data, monitor performance data, corrective actions taken, any written quality improvement plan required pursuant to 40 CFR §64.8 (5.2.7) and any activities undertaken to implement a quality improvement plan, and other supporting information required to be maintained under 40 CFR Part 64 (such as data used to document the adequacy of monitoring, or records of monitoring maintenance or corrective actions).

[40 CFR § 64.9(b); 45CSR§30-5.1.c.]

5.4.11. An owner or operator of a glycol dehydration unit that meets the exemption criteria in 40 C.F.R. §63.764(e)(1)(ii) (Section 5.1.11(e)(1)(ii) of this permit) shall maintain the records specified below:

(a) The actual average benzene emissions (in terms of benzene emissions per year) as determined in accordance with §63.772(b)(2) (Section 5.3.4) of this permit.

[40 CFR § 63.774 (d)(1)]

5.5. Reporting Requirements

5.5.1. If permittee is required by the Director to demonstrate compliance with section 5.3.3~~2~~, then the permittee shall submit a testing protocol at least thirty (30) days prior to testing and shall submit a notification of the testing date at least fifteen (15) days prior to testing. The permittee shall submit the testing results within sixty (60) days of testing and provide all supporting calculations and testing data.

[45CSR13, R13-1104, 6.5.1; 45CSR§30-5.1.c.]

5.5.2. Any deviation(s) from the allowable visible emission requirement for any emission source discovered during observations using 40CFR Part 60, Appendix A, Method 9 or 22 shall be reported in writing to the Director of the Division of Air Quality as soon as practicable, but in any case within ten (10) calendar days of the occurrence and shall include at least the following information: the results of the visible determination of opacity of emissions, the cause or suspected cause of the violation(s), and any corrective measures taken or planned.

[45CSR13, R13-1104, 6.5.2]

5.5.3. Any deviation(s) from the flare design and operation criteria in Section 5.1.4 shall be reported in writing to the Director of the Division of Air Quality as soon as practicable, but in any case within ten (10) calendar days of discovery of such deviation.

[45CSR13, R13-1104, 6.5.3]

5.5.4. General reporting requirements for 40 C.F.R. Part 64 (CAM)

a. On and after the date specified in 40 CFR §64.7(a) by which the permittee must use monitoring that meets the requirements of 40 CFR 64, the permittee shall submit CAM monitoring reports with the semi-annual monitoring report under permit condition 3.5.6. Incorporation by reference within the semi-annual monitoring report is not acceptable.

b. A report for monitoring under 40 CFR 64 shall include, at a minimum, the information required under permit condition 3.5.8. and the following information, as applicable:

1. Summary information on the number, duration and cause (including unknown cause, if applicable) of excursions or exceedances, as applicable, and the corrective actions taken;

2. Summary information on the number, duration and cause (including unknown cause, if applicable) for monitor downtime incidents (other than downtime associated with zero and span or other daily calibration checks, if applicable); and
3. A description of the actions taken to implement a QIP during the reporting period as specified in 40 CFR §64.8. Upon completion of a QIP, the permittee shall include in the next summary report documentation that the implementation of the plan has been completed and reduced the likelihood of similar levels of excursions or exceedances occurring.

[40 CFR § 64.9(a); 45CSR§30-5.1.c.]

5.6. Compliance Plan

5.6.1. N/A

6.0 Emergency Generators [emission point ID(s): 002-01, 002-02]

6.1. Limitations and Standards

These engines are subject to the attached 45CSR13 General Permit G60-C029.

6.1.1. 40 C.F.R. § 63.6590 What parts of my plant does this subpart cover? (note the following section numbers match those of 40 C.F.R. §63.6590)

(c) *Stationary RICE subject to Regulations under 40 CFR Part 60.* An affected source that meets any of the criteria in paragraphs (c)(1) through (7) of this section must meet the requirements of this part by meeting the requirements of 40 CFR part 60 subpart JJJJ, for spark ignition engines. No further requirements apply for such engines under this part.

(1) A new or reconstructed stationary RICE located at an area source;
[40 C.F.R. §63.6590.]

Note: In G60-C029, the engines are subject to 40 C.F.R. part 60 subpart JJJJ, compliance with G60-C029 shall show compliance with 40 C.F.R. 63 Subpart ZZZZ.

6.2. Monitoring Requirements

6.2.1. N/A

6.3. Testing Requirements

6.3.1. N/A

6.4. Recordkeeping Requirements

6.4.1. N/A

6.5. Reporting Requirements

6.5.1. N/A

6.6. Compliance Plan

6.6.1. N/A

7.0 Engines [emission point ID(s): EN01, EN02]

(Note: In this section “this subpart” refers to 40 C.F.R. 63 Subpart ZZZZ)

7.1. Limitations and Standards

7.1.1. §63.6595 When do I have to comply with this subpart? (Note: The following section numbers match those of 40 C.F.R. §63.6595)

(a) Affected sources. (1) If you have an existing stationary SI RICE located at an area source of HAP emissions, you must comply with the applicable emission limitations and operating limitations no later than October 19, 2013.

(c) If you own or operate an affected source, you must meet the applicable notification requirements in in 40 CFR part 63, subpart A.

[40 C.F.R. §63.6595]

7.1.2. §63.6603 What emission limitations and operating limitations must I meet if I own or operate an existing stationary RICE located at an area source of HAP emissions? (Note: The following section numbers match those of 40 C.F.R. §63.6603)

(a) If you own or operate an existing stationary RICE located at an area source of HAP emissions, you must comply with the requirements in Table 2d to this subpart.

Table 2d to Subpart ZZZZ of Part 63— Requirements for Existing Stationary RICE Located at Area Sources of HAP Emissions

As stated in §§63.6603 and 63.6640, you must comply with the following requirements for existing stationary RICE located at area sources of HAP emissions:

<u>For each . . .</u>	<u>You must meet the following requirement, except during periods of startup . . .</u>	<u>During periods of startup you must . . .</u>
<u>6. Non-emergency, non-black start 2SLB stationary RICE</u>	<u>a. Change oil and filter every 4,320 hours of operation or annually, whichever comes first;¹</u>	
	<u>b. Inspect spark plugs every 4,320 hours of operation or annually, whichever comes first; and</u>	
	<u>c. Inspect all hoses and belts every 4,320 hours of operation or annually, whichever comes first, and replace as necessary.</u>	

¹Sources have the option to utilize an oil analysis program as described in §63.6625(i) in order to extend the specified oil change requirement in Table 2d of this subpart.

[40 C.F.R. §63.6603; Table 2d of 40 C.F.R. 63 Subpart ZZZZ]

7.1.3. §63.6605 What are my general requirements for complying with this subpart?

(a) You must be in compliance with the emission limitations and operating limitations in this subpart that apply to you at all times.

(b) At all times you must operate and maintain any affected source, including associated air pollution control equipment and monitoring equipment, in a manner consistent with safety and good air pollution control practices for minimizing emissions. The general duty to minimize emissions does not require you to make any further efforts to reduce emissions if levels required by this standard have been achieved. Determination of whether such operation and maintenance procedures are being used will be based on information available to the Administrator which may include, but is not limited to, monitoring results, review of operation and maintenance procedures, review of operation and maintenance records, and inspection of the source.

[40 C.F.R. §63.6605]

7.1.4. § 63.6640 How do I demonstrate continuous compliance with the emission limitations and operating limitations? (Note: The following section numbers match those of 40 C.F.R. §63.6640)

(a) You must demonstrate continuous compliance with each emission limitation and operating limitation in Table 2d to this subpart that apply to you according to methods specified in Table 6 to this subpart.

Table 6 to Subpart ZZZZ of Part 63—Continuous Compliance With Emission Limitations, Operating Limitations, Work Practices, and Management Practices

As stated in §63.6640, you must continuously comply with the emissions and operating limitations and work or management practices as required by the following:

<u>For each . . .</u>	<u>Complying with the requirement to . . .</u>	<u>You must demonstrate continuous compliance by</u>
<u>9. Existing non-emergency 2SLB stationary RICE located at an area source of HAP</u>	<u>a. Work or Management practices</u>	<u>i. Operating and maintaining the stationary RICE according to the manufacturer's emission-related operation and maintenance instructions; or</u> <u>ii. Develop and follow your own maintenance plan which must provide to the extent practicable for the maintenance and operation of the engine in a manner consistent with good air pollution control practice for minimizing emissions.</u>

(b) You must report each instance in which you did not meet each emission limitation or operating limitation in Table 2d to this subpart that applies to you. These instances are deviations from the emission and operating limitations in this subpart. These deviations must be reported according to the requirements in §63.6650.

(e) You must also report each instance in which you did not meet the requirements in Table 8 to this subpart that apply to you.

[40 C.F.R. §63.6640]

7.1.5. The permittee shall meet the applicable general provisions specified in Table 8 of 40 C.F.R. 63 Subpart ZZZZ with the exception of §§63.7(b) and (c), 63.8(e), (f)(4) and (f)(6), 63.9(b) through (e), and (g) and (h) which do not apply per 40 C.F.R. §63.6645(a)(5).

[40 C.F.R. §§ 63.6665, 63.6645]

7.2. Monitoring Requirements

7.2.1. § 63.6625 What are my monitoring, installation, collection, operation, and maintenance requirements?

Permittee shall comply with 40 C.F.R. §§ 63.6625 (e), (h) & (j).

[40 C.F.R. §63.6625]

7.3. Testing Requirements

N/A

7.4. Recordkeeping Requirements

7.4.1. § 63.6655 What records must I keep?

Permittee shall comply with 40 C.F.R. § 63.6655 (a), (b), (d) & (e).

[40 C.F.R. §63.6655]

7.5. Reporting Requirements

N/A

7.6. Compliance Plan

N/A